

APPROVED

06/17/2026

Permit Extended to 9/30/2026 on 6/17/2026



External Message Disclaimer

CAUTION: This email originated from outside of Tinley Park. DO NOT click links, open attachments or forward unless you recognize the sender and know the content is safe. Please delete or report suspicious emails to the helpdesk at x5087.

ROW/Easement Permit Application

Utility Company or Individual?:	Utility Company
Utility Company Name:	ComEd
Email	permitting@kdmengineering.com
Address	Street Address: 1 Lincoln Centre City: Oakbrook Terrace State / Province: IL Postal / Zip Code: 60181
Name	Anthony Urbina
Title/Position:	Permitting Manager
Email	permitting@kdmengineering.com
24 Hour Phone Number	(312) 794-0223
	Electrical
	Underground & Overhead
	New Construction
Description of work to include means and methods to be used:	Install new conduit via directional bore. Install new pole and three phase transformer. See plans for detailed scope of work.
Upload the plans/exhibits for review:	0000425883_001 IFA.REV.2.pdf

Have you done utility work with the Village in the last 12 months?

No

Is this an Address or Address Range?:

Address

Address

Street Address: 6851 W 159th St
City: Tinley Park
State / Province: IL
Postal / Zip Code: 60477

Is this a ROW or Easement?:

ROW

Is there an Utility work order or reference #?

Yes

Utility Work Order/Reference #:

20424464

Proposed Start Date:

11-30-2025

*Proposed Completion Date:

01-30-2026

Signature



Title:

Permit Manager

Date

11-05-2025

You can [edit this submission](#) and [view all your submissions](#) easily.

FEEDERS: G1977X 12KV (PG. 2 OF 3)
PERMITS: MUNICIPALITY (TINLEY PARK)
AREA MAPS: 487-19N
SAG TABLES: 11J, 12J

*LABEL ALL EQUIPMENT PER C7493
**MAINTAIN ALL CLEARANCES PER C7500
SOME OBJECTS ARE HIDDEN FOR CLARITY

CUSTOMER CONTACT INFO:
KERRY FARMS - JOE SHEEHAN
drjoesheehan@kerryfarms.com

DESIGNER CONTACT INFO:
NICHOLAS JADCZAK
njadczak@kdmengineering.com / (224)-760-2039

SECONDARY CONTACT:
DELANO WALKES
dwalkes@kdmengineering.com / (773)-317-2759

GENERAL NOTES:
-CONTACT ENGINEER N. JADCZAK AT LEAST TWO WEEKS PRIOR TO START OF WORK TO DISCUSS ANY QUESTIONS
-CALL JULIE AT 1-800-892-0123 AT LEAST 48 HOURS PRIOR TO START OF WORK
-COPIES OF REQUIRED PERMITS SHALL BE ON JOB SITE AT ALL TIMES
-CONTRACTOR SHALL NOT BEGIN WORK UNTIL ALL VALID PERMITS HAVE BEEN RECEIVED
-ENGINEER SHALL BE INFORMED OF ANY FIELD CHANGES TO DESIGN TO CONFIRM VALIDITY OF PERMIT/EASEMENT
-MINIMUM FIELD EXPECTATIONS TO BE MET DURING CONSTRUCTION
-BUNDLING OPPORTUNITIES: NONE

LOCATION 1: NEW TR#487191B8
- INSTALL NEW THREE-PHASE 750KVA 277/480V FEED-THRU TRANSFORMER ON CUSTOMER PROVIDED PAD. LABEL TRANSFORMER TR487191B8
- MAKE FINAL CONNECTIONS TO TRANSFORMER PRIMARY AND SECONDARY TAPS

LOCATION 2: NEW UNDERGROUND
- DIRECTIONAL BORE APPROX. 100' OF 2 RUNS OF 4" CPTPE CONDUIT, MEETING CUSTOMER CONDUIT AT PROPERTY LINE
- PULL APPROX. 440' OF 3-1/C 3/0 AL EXCCJ PRIMARY CABLE THROUGH CONDUIT

LOCATION 3: NEW POLE P#487192031
- INSTALL NEW 35'-1 CCA POLE APPROX. 52' NORTH OF P#487192024 AND SUSTAIN
- FRAME POLE FOR 12KV FUSED TERMINAL ON ALLEY ARM. SKIN 12KV PRIMARY AND INSTALL ARC PROTECTION DEVICES
- INSTALL RISER, CUTOUTS/FUSES, WILDLIFE PROTECTION, AND GROUND. LABEL FUSES 582422
- MAKE FINAL CONNECTIONS OF LOC 2 CABLE TO RISER CUTOUTS

Permit Type	Project Name	Office	Designer	Location – Reason For Work	Work Order #
MUNICIPALITY	0000425883	CRESTWOOD	Jadcza N C937987	(41.601374°, -87.785087°)	20424464
Permit Number	SR #	JWA #	Phone #	NBBE-6851 W 159TH ST,*EV CHARGING, TINLEY PARK	Schedule Group
PENDING	06659582	N/A	(224) 760-2039		5DB
Joint Work Contact	SER/CWA #	Phone RO #	PD #	Town or Township	QS/Block
N/A	N/A	N/A	N/A	TINLEY PARK; BREMEN TWP	487191, 487192
Date Issued: PENDING		Contingent WO #s	N/A	Completed By:	Date:
0.0 77.0 153.9 FT		Page 1 of 1		Verified By:	Date:

